

Diesel / Gasoil

Date of sampling: 08.02.2017

Samples taken by: independent inspectors

TEST	UNIT	METHOD	RESULT
Ash	% m/m	ISO 6245	< 0.001
Carbon residue (10%)	% m/m	EN ISO 10370	< 0.10
Cetane index	-	EN ISO 4264	54.0
Cetane number	-	EN ISO 5165	-
Cloud point	°C	EN 23015	- 6
Cold filter plugging point	°C	EN 116	- 18
Colour (ASTM)	-	ISO 2049	L1.0
Conductivity	pS/m	ISO 6297	127
Copper corrosion (3 hrs at 50°C)	rating	ISO 2160	1a
Density at 15°C	kg/m ³	EN ISO 12185	-
Dist: Recovered at 250°C	% v/v	EN ISO 3405	43.5
Dist: Recovered at 350°C	% v/v	EN ISO 3405	94.8
Flash point	°C	ISO 2719 A	61.0
Lubricity	µm	EN ISO 12156-1	450
Oxidation stability	g/m ³	EN ISO 12205	-
Sulphur content	mg/kg	EN 20846	7.4
Viscosity at 40°C	CST	EN ISO 3104	2.439
Water content	mg/kg	EN ISO 12937	50