

# Diesel / Gasoil

**Date of sampling: 16.06.2017**

**Samples taken by: independent inspectors**

TEST	UNIT	METHOD	RESULT
Ash	Wt %	ISO 6245	< 0.001
Carbon residue (10%)	Wt %	ISO 10370	< 0.10
Cetane index	-	EN ISO 4264	53.5
Cetane number	-	EN 15195	54.3
Cloud point	°C	EN 23015	- 7
Cold filter plugging point	°C	EN 116	- 22
Colour (ASTM)	-	ISO 2049	L1.0
Conductivity	pS/m	ISO 6297	198
Copper corrosion (3 hrs at 50°C)	rating	ISO 2160	1a
Density at 15°C	kg/m <sup>3</sup>	ISO 12185	-
Dist: Recovered at 250°C	% v	ISO 3405	43.8
Dist: Recovered at 350°C	% v	EN ISO 3405	96.1
Flash point	°C	ISO 2719 A	57.5
Lubricity	µm	ISO 12156-1	430
Oxidation stability	g/m <sup>3</sup>	EN ISO 12205	2
Sulphur content	mg/kg	ISO 20846	8.2
Viscosity at 40°C	CST	EN ISO 3104	2.401
Water content	mg/kg	EN ISO 12937	40